



RECEIVED
N.C. Dept. NRCD

OCT 25 1989



G & H OIL EQUIPMENT, INC.

Winston-Salem
Regional Office

October 23, 1989

NC Department of Natural Resources
& Community Development
Div. of Environmental Management -
Groundwater Section
8025 North Point Blvd., Suite 100
Winston Salem, NC 27106-3295

Subject: Tank Closure
New Home Building Supply
1715 Spring Garden Street
Greensboro, NC

Gentlemen:

G & H has completed the excavation and removal of one (1) 2,000 gallon gasoline storage tank at the subject location.

The tank was found in good condition and no site contamination was suspected. Certificate of tank disposal from Safeway Tank Disposal, Inc. is attached.

Two soil samples were taken from beneath tank and delivered to Guilford Laboratories for total petroleum hydrocarbon analysis. Attached test results indicate less than 15 and less than 14 p.p.m.

Please call if you have any questions.

Sincerely yours,

William V. Hill
Vice President

Copy to: New Home Building Supply

Customer

Date Oct. 6, 1989

G+H Oil Equipment
P.O. Box 7446
Greensboro NC 27417

Transported by: G+H

Tanks were disposed in accordance with API 1604, 1987 Removal and Disposal of Used Underground Petroleum Storage Tanks. Residue was disposed in accordance with U.S. EPA Regulations by licensed subcontractor. Lead free scrap steel was recycled by

United Metal Recyclers on Oct. 6, 1989

Bruce A. Lyons
SAFeway TANK DISPOSAL, INC.



GUILFORD LABORATORIES, INC.
P.O. Box 9735/Plaza Station/Greensboro, N.C. 27408

October 16, 1989

REPORT OF ANALYSIS

JOB #: GH90928

CUSTOMER: G & H Oil Equipment Inc ATTN: Bill Hill

SAMPLE: # 4223 NEW HOME BUILDERS FILL SAMPLE
4224 NEW HOME BUILDERS SAMPLE #2

<u>RESULTS</u>	<u>4223</u>	<u>4224</u>
Total Petroleum Hydrocarbons (ppm)	<15	<14

Guilford Laboratories, Inc.

J. A. Rayburn
J. A. Rayburn